



GUARDIAN
INDUSTRIAL DOORS

GUARDIANDOORS.COM

0800 783 6602

ROLLER SHUTTERS - SECTIONAL OVERHEAD DOORS - INSULATED DOORS - FOLDING DOORS
STEEL DOORS - FIRE RATED DOORS - SECURITY DOORS - SLIDING GATES - HIGH SPEED DOORS

REPAIR WORKSHEET

Veolia ES (UK) Limited
Burnt Mills Industrial
Estate Archers Field Road
Basildon
Essex
SS13 1DN

Job No. R51184
Date 16/03/2023
Asset No. 1242-12421
Contact Greg Bennie
Phone 0203 567 4250





GUARDIANDOORS.COM

0800 783 6602

ROLLER SHUTTERS - SECTIONAL OVERHEAD DOORS - INSULATED DOORS - FOLDING DOORS
STEEL DOORS - FIRE RATED DOORS - SECURITY DOORS - SLIDING GATES - HIGH SPEED DOORS

REPAIR WORKSHEET

Veolia ES (UK) Limited
Burnt Mills Industrial
Estate Archers Field Road
Basildon
Essex
SS13 1DN

Job No. R51184
Date 16/03/2023
Asset No. 1242-12420
Contact Greg Bennie
Phone 0203 567 4250

Site	Burnt Mills Industrial Estate, Archers Field Road, Basildon , SS13 1DN		
Asset	Model	Location	Size
1242-12420	ECO ELECTRIC SINGLE PHASE	DOOR 3 Outside right	5400x4375
Date	Duration	Outcome	Further Works?
16/03/2023	00:27	Safe to use	Yes
Reported Fault	damage to runners due to high winds - sending photos over		
Work Completed	Assessed damage to door, Removal of guides required in order to reallign curtain and replace damaged steel endlocks. Outside LH guide needs to be redrilled, tapped and countersunk. Guide to be refitted and door tested and left in working order.		
Internal Image			
External Image			
Risk Assessment			



GUARDIANDOORS.COM

0800 783 6602

ROLLER SHUTTERS - SECTIONAL OVERHEAD DOORS - INSULATED DOORS - FOLDING DOORS
 STEEL DOORS - FIRE RATED DOORS - SECURITY DOORS - SLIDING GATES - HIGH SPEED DOORS

Risk Assessment Statement	In our opinion the door is safe to use at the time this repair has been finished.
Further Works	Yes - estimate to follow

